Utah Department of Environmental Quality Division of Drinking Water

Public Water System Inventory Report

Run Date: 08/04/2011 12:04 pm

PWS ID: UTAH11048 Name: RAINBOW RANCHOS

Legal Contact RAINBOW RANCHOS Rating: Approved

Rating Date: 06/24/1996
Activity Status: Active

Address: 3323 S 5175 W

CEDAR CITY, UT 84720

Phone Number: 435-586-7174

City Served (Area):

County: IRON COUNTY

Gal/Day Gal/Min

System Type: Community

Last Inv Update: 05/11/2011

Avg Daily Prod:

Activity Status Cd: Active

Last Snty Srv Dt: 12/31/2010

Total Dsgn Cap:

Surveyor: KATE JOHNSON

Total Emerg Cap:

Oper Period: 1/1 to 12/31

Contacts

Contact Phone Numbers

Type Name Title Office Emergency Email Address

AC RAINBOW MEADOW RANCHOS

Service Connections

 Connection Type
 Meter Type Code
 Meter Size
 Number Connections

 Residential
 Metered
 0
 71

 71
 Total Syc Connections

Storage

Total Storage: 302,000 GAL Number of Units: 2 Adequate Capacity: NO

				Constr	Overflow	Activity	
No.	Name	Type	Effective Volume	Matri	Elev	Status	Press'd
ST001	RAINBOW RANCHOS TANK	Ground	35,000 GAL	Steel		А	NO
ST002	RAINBOW RANCHOS NEW TANK	Ground	267,000 GAL	Steel		Α	NO

Treatment Plants

No. Plant Name Approved Design Capacity (gal/day) Status Process

TP001 1996 WELL CHLORINATOR A

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	RAINBOW RANCHOS PUMP STA	TI A		Р			

Distribution System

	Total Dy	n Head	Pressure	Cross	Auhority	
Pump Type	ft H2O	P.S.I.	Adequate	Connection	Statement	
			No			

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	OLD WELL	Active	WL	8	27 GPM	60 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	1996 WELL	Active	WL	8	1000 GPM	1,000 GPM	Yes	GW	Permanent	1/1 to 12/31	

 $^{^*}$ Reports measured flow for wells, approved design capacity for all other sources.